52747 250 Hp, 2300V, 8188 DP

■ Nameplate Information	<u>x</u>
<u>F</u> ile	
WinVis Mo	tor Nameplate and Test Information
Identification	Manufacturer
Motor ID: 52747 Circuit:	Mfg. Name: GENERAL ELECTRIC Mfg. Model:
	5-40260 Fibrilizer #1 N Serial Num.
Asset ID: Motor Type: AC Induction	Mfg. Date:
Nameplate Information	Bearing Information Brushes Information
Volts: 2300 Horsepower: 250 Kilowatts: 186.5 Full Load Amps: 54 Operating Speed: 1175 Min/Base Speed:	Inboard Bearing Num: Inboard Bearing Type: Outboard Bearing Num: Outboard Bearing Type: Brush Grade: Dimensions: Number of Brushes: Min. Brush Length:
Install Date: Efficiency: 0.92 Insulation Type: F Service Factor: 1.15 Power Factor: 0.85 Frame Num: 8188 Field Volts: Field Current: Num of Bars: Num of Slots: 0	Armature Information Num. of Poles: Num. of Comm. Bars: Armature Type: Cool Method:
MCE Stator AC Standard 05/30/06 PI 05/30/06 RIC 05/30/06	09:37 AM

52747(MCE Stator / AC Standard)						
<u>File E</u> dit						
Test Date	11/04/2004	05/26/2006	05/30/2006	05/30/2006		
Test Time	10:18:54 AM	09:10:39 AM	09:00:39 AM	09:26:07 AM		
	Baseline					
Frequency	1200	1200	1200	1200		
Mohm Ph 1 to Gnd						
Charge Time	30	15	15	15		
Voltage	1000	1000	1000	1000		
Motor Temp	41	28	26	26		
Measured Mohm	> 2000	0.9	0.3	0.3		
Corrected Mohm	OVR (MCE)	0.4	0.1	0.1		
pF Ph 1 to Gnd	39750	83250	77250	82500		
ohm Ph 1 to 2	0.94950	0.79650	0.79400	0.79950		
ohm Ph 1 to 3	0.94600	0.80100	0.79400	0.79550		
ohm Ph 2 to 3	0.94650	0.80150	0.79250	0.79950		
mH Ph 1 to 2	50.350	49.720	45.300	49.180		
mH Ph 1 to 3	47.580	41.820	45.350	52.150		
mH Ph 2 to 3	42.680	45.960	51.650	55,150		
Avg. Inductance	46.870	45.833	47.433	52.160		
% Res. Imbalance	0.23	0.40	0.13	0.33		
% Ind. Imbalance	8.94	8.76	8.89	5.73		
\$ Power Loss	10.84	15.48	4.65	12.39		
Test Location	T-Leads	T-Leads	Motor Leads	Motor Leads		
MCE #	030363	030363	030363	030363		
User						
Notes	Yes	Yes	Yes	Yes		

On Friday morning, this motor was running when an operator decided to wash the pulp from the side of the motor. The ground fault opened the breaker.

An electrician megged the motor windings before trying to restart it.

The megger reading stayed low over the weekend despite applying DC amperage from a welding machine.

On Tuesday we ran the motor on 460 volts in the shop.

52747 250 Hp, 2300V, 8188 DP











