

September 5, 2011

Test Your Knowledge, Part 11

IEEE43-2000 is the Recommended Practice for Testing Insulation Resistance of Rotating Machinery. Section 11.2 Suitability for Operation or Continued Testing, suggests that machines rated 10,000 kVA and less should have which of the following for continued operation or further overvoltage tests:

- A. A Polarization Index test above the minimum recommended value
- B. Temperature corrected insulation resistance above the recommended value
- C. Either A or B
- D. Both A and B

Answer: C, Either A or B. For more information see IEEE43-2000.

You are invited to submit an Electric Motor Testing Tip of your own and receive a free PdMA mug or hat if we publish it! Contact Lou at 813-621-6463 ext. 126 or lou@pdma.com.

Copyright 2011 PdMA Corporation. All rights reserved. The PdMA Tip of the Week is produced by PdMA. PdMA shall not be liable for any errors or delays in the content, or for any actions taken in reliance thereon.